Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2 : AEx e : AEx ta

#### DADT NUMBERS

CERTIFICATION:





### PRODUCT DESCRIPTION

"ABCF" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex db, IP sealing and have been tested to IP66 and IP68 to 50 metres. The "ABCF" version is designed to accommodate unarmoured and armoured cables where sealing and retention is required only on the outer sheath and additionally provides a male thread for the connection of conduit.

### COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31 IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529 UL514B, UL1203, UL2225, UL50E, ANSI/UL 60079-0/7 & ISA 60079-31

## ATEX II 1D 2G Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da

II 3G Ex nR IIC Gc

IECEx Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da

NEC - USA Class II Division 1, Groups E, F & G

(except size 25) Class I Zone 1 AEx e IIC Gb

Class II Zone 20 AEx ta IIIC Da
Class III, Enclosure Type 4X

1Ex d IIC Gb X / 1Ex e IIC Gb X / 2Ex nR IIC Gc X / Ex ta IIIC Da X

INMETRO - Brazil Ex db IIC Gb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da

SAC - China Ex d IIC Gb / Ex e IIC Gb

UKRAINE II 2G Ex db IIC Gb / II 2G Ex eb IIC Gb / II 3G Ex nR IIC Gc / II 1D Ex ta IIIC Da

CCoE - India Ex d IIC Gb (Zone 1) Ex e IIC Gb (Zone 2) Ex nR IIC Gc (Zone 2)

ABS Specified ABS Rules

 LLOYD'S
 Ex d IIC Gb / Ex e IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da

 RMRS
 Ex d IC / Ex d IIC / Ex e IC / Ex e IIC / Ex ta IIIC

ATEX SIRA 01ATEX1270X & SIRA 09ATEX1221X

 IECEx
 IECEx SIR 05.0020X

 NEC - USA
 CSA 2627370

**EAC** RU C-GB.BH02.B.00693-18

INMETRO - Brazil NCC 13.2187 X

SAC - China NEPSI GYJ16.1398X
UKRAINE CLI 18.0321 X

CCoE - India PESO P365300/2 & P365300/6

ARS 14-I D463991-1-PDA

LLOYD'S 10/00056(E1)
RMRS 14.02755.315

	- B	
A		

### 4PLE PART NUMBERING: A8CFBFM20/NP/20/M20 Gland designed for use with Unarmoured Cables Silicone Seal for Flat Cables CF Female Conduit Connection Thread Brass (B) / Stainless Steel (S) Multiple Certification M20 x 1.5 Female Conduit Connection Thread L Locknut (material dictated by gland entry thread material) Including IP Washer, Nylon (N) - Fibre (V) - PTFE (H) N SNOILI т Including Earth Tag s Including Serrated Washer Quantity per kit NP Nickel Plated Gland shell size M20 x 1.5 Male Entry Thread

LOCKN	UT	Brass (ACBLN) / Stainless Steel (ACSLN)						
EARTH	TAG	Brass (ACBET) / Stainless Steel (ACSET)						
IP WAS	HERS	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)						
SERRA	TED WASHERS	Stainless Steel (ACSSW)						
IP RATI	NG:	IP66 & IP68 (50 metres - 7 Days), Type 4X						
OPERA	TING TEMP:	Silicone Seals -60°C to +180°C						
MATER	IALS:	Brass or Stainless Steel						
PLATIN	IG:	Electroless Nickel						

Gland Size	Entry Thread Size		Metric	Connection Thread Options		Cable Outer Sheath [D]				Nominal	Dimensions/Weight (Metric Versions)		
			Thread Length			Width		Thickness		Protrusion Length [L]	Dimensions/ weight (Metric Versions)		
	Metric	NPT	[B]	Metric	NPT	Min	Max	Min	Max	(Metric)	Across Flats [A]	Across Corners	Weight (Kgs)
208	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	6.3	11.7	4.0	7.0	45	30.0	33.0	0.174
20R	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	8.1	13.5	5.8	6.2	46	30.0	33.0	0.175
20	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	10.3	13.5	5.6	9.0	45	30.0	33.0	0.174
**25	M25 x 1.5	3/4" or 1"	16	M25 x 1.5	3/4" or 1"	10.6	16.2	4.0	7.0	48	37.6	41.4	0.194

# TES

GLAND SELECTION TABLE (ALL DIMENSIONS IN mm)

- \*\* Size 25mm is only currently ATEX, IECEx, INMETRO, EAC and Ukraine certified.
- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supply products with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.
- Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.