



# TEST CERTIFICATE

ISSUED BY SIRA TEST & CERTIFICATION LIMITED

## TEST FOR THE INGRESS PROTECTION OF AN A112N ALARM SOUNDER

**Manufacturer:** European Safety Systems  
Impress House  
Mansell Road  
Acton  
London W3 7QH

**Model or Type Identification:** A112N alarm sounder

**Standard:** BS EN 60529:1992 Inc Amendments Nos 1 and 2

**Deviations from Standard:** None

**ST&C Test Procedure:** LOP 220

**ST&C Test Reports:** N58D22760A, 10/0401 and 10/0441

**Sample Delivery Date:** 16 July 2010

**Tests Conducted Between:** 20 July and 10 August 2010

This certificate refers to the performance of the test sample when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

Sira Test & Certification Limited being a UKAS accredited Test House in accordance with ISO/IEC 17025 has tested the above A112N alarm sounder and has found it to meet the requirements of the Ingress Protection Code: IP 66.

**S P CORK**  
Technical Manager

Dated 26 November 2010

*This certificate may only be reproduced in its entirety and without change*

Page 1 of 1

Certificate No: Sira 58D22760D  
FORM 6240, Issue 8