

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx SIR 07.0097X	issue No	o.:0	Certificate history:
Status:	Current			
Date of Issue:	2007-11-21	Page 1	of 3	
Applicant:	Peppers Cable Gland Stanhope Road Camberley Surrey GU15 3BT United Kingdom	ls Limited		
Electrical Apparatus: Optional accessory:	E1WF, D1WF and CWL	E Cable Gland Ranges		
Type of Protection:	Flameproof, Increased	Safety and Dust		
Marking:	E1WF and D1WF Ex d IIC/Ex e II/ Ex tD A CWLe Ex e II/Ex tD A21 IP6X.	A21 IP6X		
Approved for issue on be Certification Body:	ehalf of the IECEx	C Ellaby		
Position:		Certification Officer	A Da	
Signature: (for printed version)		C	. The same of the	$\overline{)}$
Date:		200	07-11-21	
2. This certificate is not t	chedule may only be reprod transferable and remains the nticity of this certificate ma	ne property of the issuing	body. e Official IEC	Ex Website.

SIRA Certification Service Rake Lane **Eccleston**

Chester CH4 9JN **United Kingdom**





IECEx Certificate of Conformity

Certificate No.:

IECEx SIR 07.0097X

Date of Issue:

2007-11-21

Issue No.: 0

Page 2 of 3

Manufacturer:

Peppers Cable Glands Limited

Stanhope Road Camberley Surrey GU15 3BT United Kingdom

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2004

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 4.0

IEC 60079-1: 2003

Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'

Edition: 5

IEC 60079-7: 2001

Electrical apparatus for explosive gas atmospheres - Part 7: Increased safety 'e'

Edition: 3

IEC 61241-0 : 2004 Edition: 1

Electrical apparatus for use in the presence of combustible dust - Part 0: General

requirements

IEC 61241-1: 2004

Electrical apparatus for use in the presence of combustible dust - Part 1: Protection by

Edition: 1 enclosures "tD"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/SIR/ExTR07.0132/00

Quality Assessment Report: GB/SIR/QAR06.0018/00



IECEx Certificate of Conformity

Certificate No.:

IECEx SIR 07.0097X

Date of Issue:

2007-11-21

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

All cable gland families and stopper box ranges manufactured by Pepper's Cable Gland's Limited have type code designations. These are shown in a matrix detailed in the manufacturer's documents, they are also shown in the manufacturer's instruction leaflets for the end user. These codes are unique to each and every cable gland and stopper box, and identify the various design options applicable to each cable gland family and stopper box range. A full description of the E1WF, D1WF and CWLE Cable Gland Ranges can be found in the Annexe to this Certificate.

CONDITIONS OF CERTIFICATION: YES as shown below:

- The ranges of cable glands are certified with one specific size of FLP sealing ring per gland size as supplied.
- 2. The ranges of cable glands shall not be used in enclosures where the temperature, at the point of entry/mounting is outside the range:
 - -20°C to +85°C for neoprene (black) seal variants
 - -60°C to +180°C for the silicone (white or red) seal variants
- 3. The interface between the male thread of the products and their associated enclosure cannot be defined. Therefore, it is the user's responsibility to ensure that the appropriate ingress protection level is maintained at these interfaces.