

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150707-E230764  
**Report Reference** E230764-20150702  
**Issue Date** 2015-JULY-07

**Issued to:** European Safety Systems Ltd  
Units 18 & 20, Impress House  
MANSELL ROAD, ACTON  
London  
W3 7QH UNITED KINGDOM

**This is to certify that  
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN  
HAZARDOUS LOCATIONS, AUDIBLE-SIGNAL  
APPLIANCES FOR USE IN ZONE CLASSIFIED  
HAZARDOUS LOCATIONS

Class I, Division 1, Groups A, B, C and D Hazardous  
Locations; Loudspeakers: Model number D1x, followed by  
L1 or L2, followed by -, followed by V070, R008 or R016.  
Class II, Division 1, Groups F and G Hazardous Locations.  
Loudspeakers: Model number D1x, followed by L1 or L2,  
followed by -, followed by V070, R008 or R016. Followed by  
-D.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See next page for standards.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150707-E230764  
**Report Reference** E230764-20150702  
**Issue Date** 2015-JULY-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations  
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations  
CSA C22.2 NO. 30-M1986, Explosion Proof Enclosures for use in Class I Hazardous Locations  
CSA C22.2 NO. 205-12 Signal Equipment  
UL 1480, Speakers for Fire Alarm, Emergency, and Commercial and Professional use  
UL 50E Enclosures for Electrical Equipment, Environmental Considerations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

