

EU-TYPE EXAMINATION CERTIFICATE



[1]

[2]

**Equipment or Protective System intended for use
in Potentially Explosive Atmospheres
Directive 2014/34/EU**

[3]

EU-Type Examination Certificate Number: **DEMKO 15 ATEX 1448X Rev. 2**

[4]

Product: **GNEx range of Signalling Beacons and GNExJ2 Junction Box**

[5]

Manufacturer: **European Safety Systems Limited**

[6]

Address: **Impress House, Mansell Road, Acton, London, W3 7QH, United Kingdom**

[7]

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

[8]

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive. The examination and test results are recorded in confidential report no. **4787312280**

[9]

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012+A11:2013

EN 60079-1:2014

EN 60079-31:2014

[10]

If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

[11]

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

[12]

The marking of the equipment or protective system shall include the following:

II 2 G Ex db IIC T6...T4 Gb

II 2 D Ex tb IIIC T80°C...T130°C Db

Ta -50°C to +70°C
Or as specified in table below

Certification Manager
Jan-Erik Storgaard

This is to certify that the sample(s) of the Equipment described herein ("Certified Equipment") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Equipment Certification Program Requirements. This certificate and test results obtained apply only to the equipment sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured equipment. UL has not established Follow-Up Service or other surveillance of the equipment. The Manufacturer is solely and fully responsible for conformity of all equipment to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2015-11-24

Re-issued: 2016-06-30



Notified Body

UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

[13]

Schedule

[14]

EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 15 ATEX 1448X Rev. 2

[15]

Description of Product

The GNExB1, GNExB2 series are a range of Electronic Strobe and LED Beacons housed in a Flameproof / Dust protected GRP enclosure that are intended to be used as visual warning / signaling devices. The enclosure is accessible via a threaded cover which incorporates a glass dome, the glass dome is cemented into the cover. The range is supplemented by a GNExJ2 Junction Box which is based on the GNExB2 Series enclosure, the junction box is closed with a single piece molded threaded cover.

Small Strobe Beacons

GNExB1X05DC012, GNExB1X05DC024, GNExB1X05DC048, GNExB1X05AC115, GNExB1X05AC230.

Large Strobe Beacons

GNExB2X10DC024, GNExB2X10DC048, GNExB2X10AC115, GNExB2X10AC230, GNExB2X15DC024, GNExB2X15DC048, GNExB2X15AC115, GNExB2X15AC230, GNExB2X21DC024, GNExB2X21DC048, GNExB2X21AC115, GNExB2X21AC230.

Large LED Beacons

GNExB2LD2DC024, GNExB2LD2AC115, GNExB2LD2AC230

Junctions Box

GNExJ2

Performance testing

The optical radiation output of the LED Beacons with respect to explosion protection, according to Annex II clause 1.3.1 of the Directive 2014/34/EU is not covered in this certificate.

Temperature range

Type Designation	T Class (Dust) Ambient Range -50°C to +70°C	T Class (Gas) Ambient Range -50°C to +40°C	T Class (Gas) Ambient Range -50°C to +55°C	T Class (Gas) Ambient Range -50°C to +65°C	T Class (Gas) Ambient Range -50°C to +70°C
GNExB1X05DC012	T110°C	T6	T5	-	T4
GNExB1X05DC024	T110°C	T6	T5	-	T4
GNExB1X05DC048	T110°C	T6	T5	-	T4
GNExB1X05AC115	T110°C	T6	T5	-	T4
GNExB1X05AC230	T110°C	T6	T5	-	T4
GNExB2X10DC024	T95°C	-	T6	-	T5
GNExB2X10DC048	T95°C	-	T6	-	T5
GNExB2X10AC115	T95°C	-	T6	-	T5
GNExB2X10AC230	T95°C	-	T6	-	T5
GNExB2X15DC024	T120°C	T5	-	-	T4
GNExB2X15DC048	T120°C	T5	-	-	T4
GNExB2X15AC115	T120°C	T5	-	-	T4
GNExB2X15AC230	T120°C	T5	-	-	T4
GNExB2X21DC024	T130°C	-	-	-	T4
GNExB2X21DC048	T130°C	-	-	-	T4
GNExB2X21AC115	T130°C	-	-	-	T4
GNExB2X21AC230	T130°C	-	-	-	T4
GNExB2LD2DC024	T85°C	-	-	T6	T5
GNExB2LD2AC115	T85°C	-	-	T6	T5
GNExB2LD2AC230	T85°C	-	-	T6	T5
GNExJ2	T80°C	-	-	-	T6

[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

DEMKO 15 ATEX 1448X Rev. 2

Electrical data

Type Designation	Description	Rated Voltage Range	Rated Current (mA)	IP Rating
GNExB1X05DC012	5J Xenon Strobe 12Vdc	10-14Vdc	587	IP66
GNExB1X05DC024	5J Xenon Strobe 24Vdc	20-28Vdc	266	IP66
GNExB1X05DC048	5J Xenon Strobe 48Vdc	42-54Vdc	175	IP66
GNExB1X05AC115	5J Xenon Strobe 115Vac, 50/60Hz	110-125Vac, 50/60Hz	121	IP66
GNExB1X05AC230	5J Xenon Strobe 230Vac, 50/60Hz	220-240Vac, 50/60Hz	88	IP66
GNExB2X10DC024	10J Xenon Strobe 24Vdc	20-28Vdc	592	IP6X
GNExB2X10DC048	10J Xenon Strobe 48Vdc	42-54Vdc	233	IP6X
GNExB2X10AC115	10J Xenon Strobe 115Vac, 50/60Hz	110-125Vac, 50/60Hz	399	IP6X
GNExB2X10AC230	10J Xenon Strobe 230Vac, 50/60Hz	220-240Vac, 50/60Hz	198	IP6X
GNExB2X15DC024	15J Xenon Strobe 24Vdc	20-28Vdc	882	IP6X
GNExB2X15DC048	15J Xenon Strobe 48Vdc	42-54Vdc	358	IP6X
GNExB2X15AC115	15J Xenon Strobe 115Vac, 50/60Hz	110-125Vac, 50/60Hz	383	IP6X
GNExB2X15AC230	15J Xenon Strobe 230Vac, 50/60Hz	220-240Vac, 50/60Hz	265	IP6X
GNExB2X21DC024	21J Xenon Strobe 24Vdc	20-28Vdc	1032	IP6X
GNExB2X21DC048	21J Xenon Strobe 48Vdc	42-54Vdc	460	IP6X
GNExB2X21AC115	21J Xenon Strobe 115Vac, 50/60Hz	115Vac, 50/60Hz	464	IP6X
GNExB2X21AC230	21J Xenon Strobe 230Vac, 50/60Hz	230Vac, 50 Hz	310	IP6X
GNExB2LD2DC024	LED Beacon, 24Vdc	18-54Vdc	336	IP6X
GNExB2LD2AC115	LED Beacon, 115ac, 50/60Hz	103.5-126.5Vac, 50/60Hz	124	IP6X
GNExB2LD2AC230	LED Beacon, 230ac, 50/60Hz	207-253Vac, 50/60Hz	83	IP6X
GNExJ2	GNEx Junction Box	260Vac, 60Vdc	5W	IP6X

Installation instructions

Unused apertures shall be closed with suitably certified; IP66 or IP6X rated blanking elements, maintaining the type of protection of the equipment. Cable entry temperature may exceed +70°C / the cable branching point may exceed 80°C. Therefore suitable heat resisting cables and cable glands must be used, with a rated service temperature as stated in the installation instructions.

For ambient temperatures below -10 °C and above +60 °C use field wiring suitable for both minimum and maximum ambient temperature.

Mounting instructions

GNExB2X21..... models shall be restricted to mounting with lamp up and sideways. Refer to the manufacturer's instructions.

Routine tests

Each GNExB1X enclosure shall be subjected to a routine overpressure test of at least that stated on scheduled drawing D155-00-001-SC Revision H for at least 10 s as required by clause 16.1 of EN 60079-1: 2014. There shall be no sign of damage, deformation or rupture that will invalidate the concept of protection.

Each GNExB2X, GNExB2LD2 and GNExJ2 enclosure shall be subjected to a routine overpressure test of at least that stated on scheduled drawings D156-00-001-SC Revision G, D156-00-401-SC Revision A and D156-00-501-SC Revision E for at least 10 s as required by clause 16.1 of EN 60079-1: 2014. There shall be no sign of damage, deformation or rupture that will invalidate the concept of protection.

[16]

Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17]

Specific conditions of use:

- The enclosure is non-conducting and may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
- Accessible metal parts are capable of retaining a stored capacitance of 10pF therefore the end user shall take the appropriate action to reduce the risks of ignition associated with discharging this capacitance.
- Repair of the flamepaths is not permitted.
- GNExB2X21 models shall not be mounted with the lamp down.

[13]

Schedule

[14]

EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 15 ATEX 1448X Rev. 2

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9. In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause

1.2.7

1.4


Subject

Protection against other hazards

Hazards arising from external effects

Additional information

The GNExB1X05DC012, GNExB1X05DC024, GNExB1X05DC048, GNExB1X05AC115 and GNExB1X05AC230 have in addition passed the tests for Ingress Protection to IP 66 in accordance with EN60529:1991+A1:2000+A2:2013.

The trademark  will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.