Peppers Cable Glands Limited


Stanhope Road, Camberley, Surrey, GU15 3BT United Kingdom Telephone: +44 (0) 1276 64232 · Facsimile: +44 (0) 1276 691752 Email: sales@peppers.co.uk · Website: www.cableglands.com



Cable Gland Type CR-U (Double Compression for Unarmoured Cables)

Ex d: Ex e: Ex nR: Ex ta: IP66: IP68

Part Numbers:













CR-LIRCK1/NIP/20/M20





"CR-U" type glands, certified Flameproof Ex d, Increased Safety Ex e & Restricted Breathing Ex nR are suitable for use in Zone 1, Zone 2, Zone 21, Zone 22, Group I Mining, Gas Groups IIA, IIB, IIC and Dust Groups IIIA, IIIB, IIIC. Occasionally referred to as "potting glands", they provide a compound barrier Ex d & IP seal on the cable inner cores, eliminating damage to cables that exhibit "cold flow" characteristics and an additional environmental seal on the outer sheath. The unique features include, Peppers T-1000, the sealing compound that $enables \ a \ quick \ and \ easy installation \ and \ an innovative \ barrier \ chamber \ that \ provides \ a \ cable \ acceptance \ that \ is \ on \ average \ 17\% \ greater \ than \ other \ designs. \ The \ gland \ maintains \ IP66$ & IP68 to 100 metres and is deluge proof without the use of an additional seal or deluge boot. It is supplied with an IP O-ring seal as standard on metric entry threads.

Compliance EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31 Standard:

IEC 60079-0, IEC 60079-1, 60079-7, IEC 60079-15, IEC 60079-31 & IEC 60529 Certification: I M2 II 2GD Ex d I Mb & IIC Gb / Ex e I Mb & IIC Gb / Ex ta IIIC Da **ATEX**

II 3GD Ex nR IIC Gc

IECEx Ex d I Mb & IIC Gb / Ex e I Mb & IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc

GOST-R Ex d I & IICU / Ex e IIU CSA Ex d I & IIC Class I Zone 1 CSA AEx d IIC / AEx e II

Class I Division 2, Groups A, B, C & D Class II Division 2, Groups E, F & G Class III, Enclosure Types 3, 4 & 4X

NEPSI Ex d IIC

INMETRO BR - Ex d IIC / Ex nR II / Ex tD A21

ABS 1-1-4/7.7, 4.8-3/1.7, 4-8-3/13 and 4-8-4/27.5

MODU Rules 4-3-3/9

LLOYD'S Enclosure Systems (Part 1B)

RMRS Part XI of Rules for sea-going ships (ed.2008)

ATFX SIRA 03ATEX1479X & SIRA 09ATEX4124X Certificate No.

> **IECEx** SIR 07.0098X GOST-R POCC GB.F506.B00853 CSA CSA 1356011 NFPSI GYJ06188X INMETRO NCC 5881/09 X ABS 09-LD463991A-PDA LLOYD'S


10/00056 **RMRS** 09.00784.011

IP Rating: IP66 & IP68 (100 metres - 7 Days), NEMA 4X & DTS01 1991

-60°C to +135°C Temperature: Materials: Brass or Stainless Steel

Plating: Nickel - Zinc Compound:

Peppers T-1000 Sealing Compound



	(See below for details)			CR-OBCR1/NF/20/M20					
	CR-U Type of gland wi			h Compound (Barrier) Inner Seal & Silicone Elastomeric					
		В	Brass (B) / Stainless Steel (S)						
	Options	C	PVC Shroud (C) - PCP Shroud (P) - LSOH Shroud (3)						
		K or V	Locknut, & Nylon (K) or Fibre (V) IP Washer						
		S	Including Serrated Washer						
		1	Quantity per kit						
		NP	Nickel Plated (NP) - Zinc Plated (ZP)						
		20	Gland shell size						
		M20	M20 Entry Thread						
	Optional Accessories		Locknut	Brass (ACBLN) / Stainless Steel (ACSLN)					
			Earth tag	Brass (ACBET) / Stainless Steel (ACSET)					
			IP Washers	Nylon (ACNSW) / Fibre (ACFSW)					
			Serrated Washers	Stainless Steel (ACSSW)					
			Shrouds	PVC (ACSPVC) / PCP (ACSPCP) / LSOH (ACSSIO)					

Curing Time: @ 21 °C

Example Part Numbering

Conductor termination can be effected after 1 hour The equipment can be energised after 4 hours Compound chamber can be fully inspected after 4 hours

CABLE GLAND SELECTION TABLE													
Gland Size	Entry Thread Size		ISO Thread Length	Cable Acceptance Details					Dimensions/Weight (Metric)			Metric	
				Cable Inner Sheath [C]		Cable Outer Sheath [D]		Nominal Protrusion				Thread	
	Metric	NPT	[B]	Number of Cores	Max Ø Over Cores	Min	Max	Length [L]	Across Flats	Across Corners [A]	Weight Kgs	Shroud Size	
16	M20 x 1.5	1/2" or 3/4"	16	15	10.4	3.4	8.4	73	25.4	28.0	0.192	EL24	
205	M20 x 1.5	1/2" or 3/4"	16	35	10.4	4.8	11.7	73	25.4	28.0	0.192	EL24	
20	M20 x 1.5	1/2" or 3/4"	16	40	12.5	9.5	14.0	73	30.0	33.0	0.258	EL30	
25	M25 x 1.5	3/4" or 1"	16	60	17.8	11.7	20.0	74	37.6	41.4	0.382	EL38	
32	M32 x 1.5	1" or 1 1/4"	16	80	23.5	18.1	26.3	80	46.0	50.6	0.578	EL46	
40	M40 x 1.5	1 1/4" or 1 1/2"	16	130	28.8	22.6	32.2	87	55.0	60.5	0.892	EL55	
50S	M50 x 1.5	1 1/2" or 2"	16	200	34.2	28.2	38.2	87	65.0	71.5	1.172	EL65	
50	M50 x 1.5	2"	16	400	39.4	33.1	44.1	87	65.0	71.5	1.036	EL65	
63S	M63 x 1.5	2" or 2 1/2"	19	400	44.8	39.3	50.1	88	80.0	88.0	1.726	EL80	
63	M63 x 1.5	2 1/2"	19	425	50.0	46.7	56.0	88	80.0	88.0	1.558	EL80	
75S	M75 x 1.5	2 1/2" or 3"	19	425	55.4	52.3	62.0	97	90.0	99.0	1.882	EL90	
75	M75 x 1.5	3"	19	425	60.8	58.0	68.0	97	90.0	99.0	1.672	EL90	
80	M80 x 2	3" or 3 1/2"	25	425	64.4	61.9	72.0	123	104.0	115.2	3.826	EL104	
85	M85 x 2	3" or 3 1/2"	25	425	69.8	69.1	78.0	123	104.0	115.2	3.238	EL104	
90	M90 x 2	3 1/2" or 4"	25	425	75.1	74.1	84.0	123	114.0	125.7	4.063	EL114	
100	M100 x 2	3 1/2" or 4"	25	425	80.5	81.8	90.0	123	114.0	125.7	3.492	EL114	
						All dimensions in I	nm						

- Gland size does not necessarily equate to the entry thread size.
- The IP O-ring seal is only available on metric entry threads. IP washers can be supplied for tapered entry threads.
- Please ensure that the IP O-ring is not used in conjunction with a flat IP washer.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Where glands are fitted into non-metallic Ex e enclosures they must be included within the earth circuit of the system.
- The user should seek expert advice if intending to combine flammable and combustible dust in one environment/installation.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supply cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length. Peppers will not be held responsible for clients' installations where this has not been taken into account.
- To maintain the specified IP rating, clearance holes must be in accordance with EN 50262 Table 1 and the entry device should be suitably secured.
- The gland is supplied with the correct amount of the two-part compound, gloves and instructions to allow one complete termination. Gland kits can be supplied with a PTFE IP washer in order to maintain the temperature range if required.