



TEST CERTIFICATE

ISSUED BY SIRA TEST & CERTIFICATION LIMITED

TEST FOR THE INGRESS PROTECTION OF AN A105N ALARM SOUNDER

Manufacturer: European Safety Systems
Impress House
Mansell Road
Acton
London W3 7QH

Model or Type Identification: A105N alarm sounder

Standard: BS EN 60529:1992 Inc Amendments Nos 1 and 2

Deviations from Standard: None

ST&C Test Procedure: LOP 220

ST&C Test Reports: N58D22760A, 10/0401 and 10/0691

Sample Delivery Date: 5 July 2010

Tests Conducted Between: 12 July and 11 November 2010

This certificate refers to the performance of the test sample when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

Sira Test & Certification Limited being a UKAS accredited Test House in accordance with ISO/IEC 17025 has tested the above A105N alarm sounder and has found it to meet the requirements of the Ingress Protection Code: IP 66.

S P CORK
Technical Manager

Dated 26 November 2010

This certificate may only be reproduced in its entirety and without change

Page 1 of 1

Certificate No: Sira 58D22760C
FORM 6240, Issue 8