



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEX Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:  issue No.:

Status:

Date of Issue: **2013-02-13** Page 1 of 4

Applicant: **European Safety Systems Ltd.**  
Inpress House  
Mansell Road  
London W3 7QH  
United Kingdom

Electrical Apparatus: **GNEx Series Sounder/Loudspeaker**  
*Optional accessory:*

Type of Protection: **Flameproof**

Marking: **Ex d II\* T\* Gb**  
\* Refer to the description

*Approved for issue on behalf of the IECEX  
Certification Body:* C Ellaby

*Position:* Deputy Certification Manager

*Signature:*  
*(for printed version)*

*Date:*

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEX Website](http://www.iecex.com).

Certificate issued by:

**SIRA Certification Service**  
Rake Lane  
Eccleston  
Chester  
CH4 9JN  
United Kingdom

**sira**  
CERTIFICATION



# IECEX Certificate of Conformity

Certificate No.: IECEx SIR 13.0029X

Date of Issue: 2013-02-13

Issue No.: 0

Page 2 of 4

Manufacturer: **European Safety Systems Ltd.**  
Inpress House  
Mansell Road  
London W3 7QH  
**United Kingdom**

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-1 : 2007-04** Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition: 6

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/SIR/ExTR13.0217/00](#)

Quality Assessment Report:

[GB/SIR/QAR06.0020/03](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx SIR 13.0029X

Date of Issue: 2013-02-13

Issue No.: 0

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows.*

The GNEx Series Sounder/Loudspeaker consists of a GRP, flameproof enclosure which contains a pressure unit that generates sound, control circuitry and terminals for connection to external circuits. The enclosure has a pressed metal wire element which is cemented into the enclosure for the transmission of sound from the enclosure. The enclosure has a threaded lid for access and cable entry is via up to two, M20 x 1.5 threaded entries. Both internal and external earthing facilities are provided.

### Condition of manufacture

The Manufacturer shall comply with the following:

1. Each enclosure shall be subjected to a routine overpressure test of at least 23.05 bar for at least 10 seconds as required by IEC 60079-1:2007 clause 16.1. There shall be no permanent deformation or damage to the enclosure and there shall be no leakage through the enclosure wall

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. The enclosure is non-conducting and, under certain extreme conditions, may generate an ignition-capable level of electrostatic charges. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.



# IECEx Certificate of Conformity

Certificate No.: IECEx SIR 13.0029X

Date of Issue: 2013-02-13

Issue No.: 0

Page 4 of 4

**EQUIPMENT(continued):**

The equipment has the following gas groups, temperature classes and ambient temperature ranges:

Type (Description)	Option (Rating)	Gas group	Temp. class	Ambient temp.
GNExS1**** (110 dB Small Sounder)	GNExS1DC024 (10 – 30 V dc) GNExS1DC048 (48 V dc) GNExS1AC230 (100 – 260 V ac/dc)	IIC	T4	-60°C to +50°C
		IIC	T3	-60°C to +70°C
		IIB	T6	-60°C to +50°C
		IIB	T5	-60°C to +65°C
		IIB	T4	-60°C to +70°C
GNExS2**** (117 dB Small Sounder)	GNExS2DC024 (10 – 30 V dc) GNExS2DC048 (48 V dc) GNExS2AC230 (100 – 260 V ac)	IIC	T4	-60°C to +50°C
		IIC	T3	-60°C to +58°C
		IIB	T6	-60°C to +50°C
		IIB	T5	-60°C to +58°C
GNExL1**** (15 W Loudspeaker)	GNExL1V100 (100/70 V Line) GNExL1R016 (16 Ohm) GNExL1R008 (8 Ohm)	IIC	T4	-60°C to +50°C
		IIC	T3	-60°C to +70°C
		IIB	T6	-60°C to +50°C
		IIB	T5	-60°C to +65°C
		IIB	T4	-60°C to +70°C
GNExL2**** (25 W Loudspeaker)	GNExL2V100 (100/70 V Line) GNExL2R016 (16 Ohm) GNExL2R008 (8 Ohm)	IIC	T4	-60°C to +50°C
		IIC	T3	-60°C to +65°C
		IIB	T6	-60°C to +50°C
		IIB	T5	-60°C to +65°C